

Odour site visit checks

Site Odour Check List Site name: Wanlip Time and Date: 10:00 17/04/24 **Print Initials: ES** Circle: Reactive of Proactive Record customer details in actions/next steps for Reactive complaints) 1. Wind direction 8. Weather conditions: Specify..... 11 mph South East 2. Flows into works/ FFT 3600 L/S High (3000-3600 L/s) Nedium (1500-3000 l/s) Low (0-1500 l/s) High Medium Actual flow - 3300 L/S 3. Odour present on site SPS? information regarding site issues etc. Yes Site is healthy -4. Screenings and grit removed from site as per contact Biffa have 3 shutter doors open agreement (Inlet, PFT and CDE)? N/W PST 4 0.0.S -No 5. Out of service PST's drained and cleaned?



No

## 6. Out of service PFT's drained and cleaned?



No

## 7. PFT and PST Red Golden Measure ALB's?



Specify – clear skies/sunny

9. Odour present at inlet channel?



Low

Actions/Next Steps/ OOS Assets/ Any additional

O/W FST 5 (valve dropped, summer job)

- CDE screens = imported sludge screens
- PST = primary settlement tanks
- PFT = Picket Fence Thickener
- SPS = sewage pumping station
- ALB = action limit breach
- L/S = Litres per second
- FFT = Full flow treatment before we divert to storm tanks

